



||| PO Box 3119 Burnley North VIC 3121
||| t. 03 9028 4265
||| e. accounts@atechproducts.com.au
||| **atechproducts.com.au**

Internal Tiling Bathrooms (Inspection and Test Procedure)

Project Details:

- Project Name:
- Project Address:
- Date of Inspection:
- Inspection No:

Purpose: The purpose of this inspection and test procedure is to ensure that the internal tiling of bathrooms meets the required standards and quality before handover to the client. This procedure aims to identify any defects, ensure proper installation, and verify that all necessary tests are conducted.

Inspection and Test Procedure:

Step	Inspection/Test	Description	Acceptance Criteria	Result
1	Tile Layout	Verify the tile layout and alignment. Ensure tiles are evenly spaced and aligned with reference lines.	Tiles are evenly spaced and aligned with reference lines.	[Pass/Fail]
2	Tile Adhesion	Check the adhesion of tiles to the substrate. Tap on tiles to identify any hollow sounds or loose tiles.	Tiles have solid adhesion to the substrate without any hollow sounds or loose tiles.	[Pass/Fail]
3	Grout Lines	Examine grout lines for consistency and uniformity. Check for any gaps, excess grout, or uneven lines.	Grout lines are consistent, uniform, and free from gaps or excess grout.	[Pass/Fail]
4	Tile Leveling	Verify that tiles are laid evenly and level across the surface. Use a straight edge or level to check for any unevenness.	Tiles are level and even across the surface.	[Pass/Fail]
5	Tile Cuts	Inspect tile cuts around edges, corners, and obstacles. Ensure they are clean, precise, and fit snugly.	Tile cuts are clean, precise, and fit snugly around edges, corners, and obstacles.	[Pass/Fail]

Step	Inspection/Test	Description	Acceptance Criteria	Result
6	Grout Color	Check that the grout color matches the desired color and is consistent throughout the installation.	Grout color matches the desired color and is consistent.	[Pass/Fail]
7	Tile Cleanliness	Assess the cleanliness of tiles and grout. Check for any adhesive or grout residue.	Tiles and grout are clean without any adhesive or grout residue.	[Pass/Fail]
8	Final Finish	Evaluate the overall appearance and finish of the tiling job.	Tiling job has a neat and professional appearance.	[Pass/Fail]

Conclusion: Based on the inspection and test results, the internal tiling in bathrooms [meets/does not meet] the required standards and quality for handover to the client.

Recommendations:

- [If the tiling meets the required standards]: No further action required.
- [If the tiling does not meet the required standards]: Identify and rectify any defects or non-conformities before proceeding with handover.

Inspection Conducted By:

- Name:
- Signature:
- Date:

Note: It is essential to conduct this inspection and test procedure in accordance with the relevant building codes, standards, and specifications. Regular inspections during tiling installation can help identify and address any issues early in the process, ensuring a successful and high-quality outcome for the project.